


Notes:

1. This is the City of Kalispell Design. A sample port is generally required as well (30" CB)
2. If INLET and outlet piping is greater than 4" than interior penetrations must match inlet and outlet
3. Use 1" Sealant
4. Drawing with Drive Over lid. City of Kalispell requires grade rings, and Sanitary sewer castings (non bolt down)
5. Reinforcement Drawings Available Upon Request.
6. Tank Designs Meet ASTM C1227, C890 & Montana DEQ Circular 4 With 6 Feet Of Bury.
7. COK wants only 1 inlet and 1 outlet. Confirm with Contractor before making. Use Cast A Seals

Approx. Weight With Standard Lid =14,100 Lbs.
Approx. Weight With Traffic Rated Lid =17,100 Lbs

	COMPANY: GLACIER PRECAST CONCRETE			CUSTOMER:			MIX:	QUANTITY:
	TITLE: 1500 Sand Oil Sperator - COK			PROJECT NAME:			CY:	SCALE: 1:25
	DRAWN BY:	DATE DRAWN:	PM:	RELEASED FOR PROD.:	APPROX. DELIVERY:	WEIGHT:	SHEET: 1/1	

